

**INSPECTORATE**

ISO 9001:2008 Certified

Certificate of Analysis

Vessel / Shore Tank : TANK 1
Product : #6 Fuel Oil
Client Reference : V-10-00281
Terminal / Port / Office : SPRAGUE SEARSPORT
Job ID : 0020-0002535
Sample Details : AFTER PENN 120
Comments :

Sample Submitted By : IAC Searsport
Analysis Performed By : IAC Portland
Date Sampled : 05-Mar-2010
Date Reported : 07-Mar-2010
Submission ID : 2010-020-00202

SP/10/0303

Sample Number		2010-020-00202-004	
Method	Test	Result	Specification
ASTM D287	API Gravity, ° API-U,M,L Calc Avg	14.3	10.0 Min
ASTM D1250	Density at 15°C	0.9699	
ASTM D4294	Sulfur Content, mass %-U,M,L Calc Avg	0.408	0.50 Max
ASTM D445	Test Temperature	50°C (122°F)	
	Kinematic Viscosity, cSt-U,M,L Calc Avg	206.6	
ASTM D2161	Test Temperature, ° F	122	
	Saybolt Furol Seconds, sec	97.9	75-300 (ssf)
ASTM D95	Water, % (v/v)	0.00	1.0 Max
ASTM D473	Sediment Content, mass % / vol %	0.06 / 0.03	0.1 Max
ASTM D1796	Water and Sediment, % (v/v)	0.100	1.0 Max
ASTM D93 Proc. B	Manual / Automated	Automatic	
	Flash Point, ° C / ° F	129.0 / 264	150 Min (F)
ASTM D482	Ash Content, mass %	0.0748	0.1 Max
IP 470	Aluminum, ppm (mg/kg)	150	
	Silicon, ppm (mg/kg)	139	
	Sodium, ppm (mg/kg)	18	60 Max
	Vanadium, ppm (mg/kg)	6	300 Max
ASTM D5762	Nitrogen, % wt	0.2489	
ASTM D240	Gross Heat of Combustion, BTU/lb	18662	
	Unit Conversion, BTU/gal	150826	
ASTM D4530	Carbon Residue, % (m/m)	7.18	21 Max
ASTM D97	Pour Point, ° C / ° F	18 / 64	60 Max (F)
ASTM D6560	Asphaltenes, % (m/m)	1.1	14 Max
ASTM D287	API Gravity, ° API		
	Upper	14.3	
	Middle	14.3	
	Lower	14.2	
ASTM D4294	Sulfur Content, mass %		
	Upper	0.411	
	Middle	0.407	
	Lower	0.406	
ASTM D445	Kinematic Viscosity, cSt		
	Upper	218.1	
	Middle	189.1	
	Lower	212.5	

SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.

Inspectorate: Signature On File

Rick Kennedy,